

Questions & Answers

Bid 2013-100-01 "Laboratory Cold Storage Room Equipment"

1) Section 13 21 26, page 3 B. 4- Temperature Range- [Will ± 1 C be acceptable versus ± 0.3 C? **YES**
Number of door openings per day?

2) Section 13 21 26, page 3 B. 5- If dehumidifier is required can it be located on the ceiling panels? **YES**

3) Section 13 21 26, page 5 2.06 A.- 1. What is the length of refrigerant line run from room to roof condensing unit? **250 ft**

Will there be an allowance in the temperature variance during electric defrost? **The question is unclear. Could you explain this further?** If so, please specify acceptable range.

General question regarding size of cold storage room: 10 x 12.5 x 9 HOLD TO exterior dimension? **Plan on A01 states 10'-0" x 12'-0" nominal outside dimensions, 9'-0" tall clear interior height**

I am having difficulty seeing the fine print on plan A01 of the cold room. Could you direct me to another source for this drawing? **Attached is copy.**